

Bonding the Control Center

Some state local codes require bonding the control center to the bonding grid. If this is required, install a bonding lug (156T11047A) to the Control Center enclosure and connect a #8 solid copper core wire, to an approved earth ground, (i.e. approved ground stake, or conducting metal water pipe buried to a sufficient depth, etc.).

